



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY

IRINJALAKUDA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qcsd.ijk@gmail.com

Test Report

Test Report. No :KWA/QCSDL/IJK-TSR/3247/2022


Report Date: 27-08-2022

Customer Name & Address			1. Date of Receipt : 24/08/2022	
SRI SAI VIDYA BHAVAN , P.O.P. VEMBALLUR , KODUNGALLUR , PIN : 680671			2. Sampling done by : The Customer	
			3. UID No. of Sample: KWA/QCSDL/IJK-TSR/S-003247/2022	
			4. Source of Sample : TREATED WATER	
			5. Sample Quantity : 100ml	
			6. Test Performing Dates From : 24/08/2022 To : 26/08/2022	
Sl. No.	Parameters	Acceptable limits as per-IS 10500- 2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	NIL
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



* End of Report *

Authorized By

Haritha T.S.
Quality Manager,
Quality Control Sub District Laboratory

KWA/QCSDL/IJK-TSR/R-No:6	Issue No:1	Issue Date 01/10/2021
Rev.No: 00	Rev Date: 00	Page 1 of 1 Irinjalakuda - 680 121